

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ ಕಛೇರಿ
ಲೋಡ, ಬೆಂಗಳೂರು ವಿಭಾಗ,
ಲೋಡ ಅನೇಕ್ ಕಟ್ಟಡ 2ನೇ ಮಹಡಿ
ಕೆ.ಆರ್.ವೃತ್ತ ಬೆಂಗಳೂರು 01



ಕರ್ನಾಟಕ ಸರ್ಕಾರ
(ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ)

ಸಂಖ್ಯೆ:ಕಾನಿಇಂ:ಬೆಂವಿ:ಎಇ-3: 23-24

“ನೋಂದಾಯಿತ ಅಂಚೆ ಮತ್ತು ಸ್ವೀಕೃತಿ”

ರವರಿಗೆ:-

Secretary,
Vishwa Vidyapeeth School,
(A Unit of C.S Education Trust),
Sy No. 72, Nekkundi, Dommasandra Road,
Varthur Hobli, Anekal Taluk, Bangalore – 560087.

ಮಾನ್ಯರೇ,

ವಿಷಯ:- C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.

- ಉಲ್ಲೇಖ:-
1. ದಿನಾಂಕ: 19.09.2020 ರಂದು ಸರ್ಕಾರದ ಪ್ರಧಾನ ಕಾರ್ಯದರ್ಶಿಗಳು, ಪ್ರಾಥಮಿಕ ಮತ್ತು ಪ್ರೌಢ ಶಿಕ್ಷಣ ಇಲಾಖೆ, ಬೆಂಗಳೂರು ರವರ ಅಧ್ಯಕ್ಷತೆಯಲ್ಲಿ ನಡೆದ ಸಭೆಯ ನಡವಳಿ.
 2. ಸರ್ಕಾರದ ಸುತ್ತೋಲೆ ಸಂಖ್ಯೆ: ಲೋಡ 59 ಬಿಇಡಿ 2019, ದಿನಾಂಕ: 10.11.2021
 3. ಸರ್ಕಾರದ ತಿದ್ದುಪಡಿ ಆದೇಶ ಸಂಖ್ಯೆ: ಲೋಡ 59 ಬಿಇಡಿ 2019, ದಿನಾಂಕ: 20.11.2021.
 4. ತಮ್ಮ ಪುನರ್ವಿ ದಿನಾಂಕ:- 12.11.2021
 5. ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಆನೇಕಲ್ ಉಪವಿಭಾಗ, ಆನೇಕಲ್ ರವರ ಪತ್ರ ಸಂಖ್ಯೆ: 2023-24/430

ಮೇಲಿನ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore ಇಲ್ಲಿನ ಕಟ್ಟಡಕ್ಕೆ ಶೈಕ್ಷಣಿಕ ಉದ್ದೇಶಕ್ಕಾಗಿ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡಲು ಉಲ್ಲೇಖ (4) ರ ಪತ್ರದಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ.

ರಿಟ್ ಪಿಟೀಷನ್ (ಸಿವಿಲ್) ಸಂ: 484 (2004) ಗೆ ಸಂಬಂಧಿಸಿದಂತೆ ಸುಪ್ರೀಂ ಕೋರ್ಟ್ ನೀಡಲಾದ ಜಡ್ಜ್‌ಮೆಂಟ್‌ನಲ್ಲಿ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ರವರು ಶಾಲಾ/ಕಾಲೇಜು ಕಟ್ಟಡಗಳನ್ನು ಪರಿಶೀಲಿಸಿ “Structurally Stable Certificate” ಅನ್ನು ನೀಡಲು ಆದೇಶಿಸಿರುವುದರಿಂದ ಹಾಗೂ ಉಲ್ಲೇಖ (1) ರ ಸಭಾ ನಡವಳಿಯ ನಿರ್ದೇಶನದಂತೆ ಈಗಾಗಲೇ ನಿರ್ಮಾಣಗೊಂಡು ಅಸ್ತಿತ್ವದಲ್ಲಿರುವಂತಹ ಕಟ್ಟಡಗಳಿಗೆ ರಚನಾತ್ಮಕ (Structural Evaluation) ಮೌಲ್ಯಮಾಪನ ಮಾಡಿಸಿ National Building code ಮಾನದಂಡಗಳ ಅನ್ವಯ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡಲು ಸೂಚಿಸಿರುವುದರಿಂದ ಪ್ರಸ್ತಾಪಿತ ಕಟ್ಟಡಕ್ಕೆ ಈ ಕೆಳಕಂಡಂತೆ ವರದಿ ನೀಡಲಾಗಿದೆ.

‘C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore’ ರವರ ಕಟ್ಟಡವನ್ನು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಲೋಕೋಪಯೋಗಿ ಉಪವಿಭಾಗ, ಆನೇಕಲ್ ಹಾಗೂ ‘Vishwa Vidyapeeth School’ ವಿದ್ಯಾಸಂಸ್ಥೆ ರವರ ನೋಂದಾಯಿತ ಸ್ಟ್ರಕ್ಚರಲ್ ಇಂಜಿನಿಯರ್ ರವರ ಉಪಸ್ಥಿತಿಯಲ್ಲಿ ಕಟ್ಟಡ ಪರಿವೀಕ್ಷಣೆ ಮಾಡಲಾಗಿದೆ ಎಂದು ವರದಿ ಮಾಡಿರುತ್ತಾರೆ.

Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

ಕಟ್ಟಡವು 2020 ರ ಇಸವಿಯಲ್ಲಿ ನಿರ್ಮಾಣಗೊಂಡಿದ್ದು, ನೆಲಮಹಡಿಯಲ್ಲಿ ಒಂದು ಪ್ರಿನ್ಸಿಪಾಲ್ ರೂಂ, ಒಂದು ಸ್ಟಾಫ್ ರೂಂ, ಹದಿನೇಳು ಕೊಠಡಿಗಳು, ಎರಡು ಕಂಪ್ಯೂಟರ್ ಲ್ಯಾಬ್, ಒಂದು ಲೈಬ್ರರಿ ಮತ್ತು ಆರ್ಟ್ ರೂಂ ಹಾಗೂ ಗಂಡುಮಕ್ಕಳಿಗೆ ಶೌಚಾಲಯ ಮತ್ತು ಹೆಣ್ಣು ಮಕ್ಕಳಿಗೆ ಶೌಚಾಲಯಗಳು ಇರುತ್ತವೆ. ಮೊದಲನೇ ಮಹಡಿಯಲ್ಲಿ ಹದಿನಾರು ಕೊಠಡಿಗಳು, ಒಂದು ಲೈಬ್ರರಿ, ನಾಲ್ಕು ಲ್ಯಾಬ್ ಹಾಗೂ ಗಂಡು ಮಕ್ಕಳಿಗೆ ಶೌಚಾಲಯ ಮತ್ತು ಹೆಣ್ಣು ಮಕ್ಕಳಿಗೆ ಶೌಚಾಲಯಗಳು ಇರುತ್ತವೆ. ಮೆಟ್ಟಿಲುಗಳ ಆಗಲವು 1.50 ಮೀಟರ್ ಇರುತ್ತವೆ.

ಮುಂದುವರೆದು, ಕಟ್ಟಡವನ್ನು ನಿರ್ಮಿಸಿ 5 ವರ್ಷಗಳಿಗಿಂತ ಕಡಿಮೆ ಅವಧಿಯಾಗಿದ್ದು, ಕಟ್ಟಡದ ದೃಢತೆಗೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಉಲ್ಲೇಖ (2) ಅಂಶ-3 ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ ಸಂಸ್ಥೆಯವರು ಈ ಕೆಳಕಂಡ ದಾಖಲೆಗಳನ್ನು ಒದಗಿಸಿರುತ್ತಾರೆ.

- ಪಂಚಾಯತಿ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ, ನೆರಿಗಾ ಗ್ರಾಮ ಪಂಚಾಯತಿ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ರವರಿಂದ C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore ಗಾಗಿ ಅನುಮೋದನೆಯಾದ ನಕ್ಷೆ.
- ಸದರಿ ಕಟ್ಟಡವನ್ನು Specs Consulting Civil Engineers ಸಂಸ್ಥೆಯ H. J. Radhakrishna Setty, Reg No. B.C.C/BL-3.6/SE-0195/2021-22 ಸಂಸ್ಥೆ ರವರು ನೀಡಿರುವ ಸ್ಪೆಕ್ಟರಲ್ ವಿನ್ಯಾಸದ ನಕ್ಷೆ.
- GEO Engineering Company Private Limited ರವರು ನೀಡಿರುವ FORM FOR CERTIFICATE FOR SUB SURFACE INVESTIGATION (Annex-1) ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಒದಗಿಸಿರುತ್ತಾರೆ.
- ಪಂಚಾಯತಿ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ, ನೆರಿಗಾ ಗ್ರಾಮ ಪಂಚಾಯತಿ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ನಿಂದ ಅನುಮೋದನೆಯಾದ ನಕ್ಷೆಯಂತೆ C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore ಕಟ್ಟಡವನ್ನು ನಿರ್ಮಿಸಲಾಗಿರುತ್ತದೆ ಎಂದು ವರದಿಮಾಡಿರುತ್ತಾರೆ. (Annex-2)
- Cambridge Infrastructures and Leasing ರವರು ನೀಡಿರುವ FORM FOR CERTIFICATE FOR COMPLETED WORK BY BUILDER/CONSTRUCTOR ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಒದಗಿಸಿರುತ್ತಾರೆ. (Annex-3)
- Cambridge Infrastructures and Leasing ರವರು ನೀಡಿರುವ FORM FOR CERTIFICATE FOR SUPERVISION OF WORK ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಒದಗಿಸಿರುತ್ತಾರೆ. (Annex-4)
- H.J. Radhakrishna Setty Structural Engineer ರವರು ನೀಡಿರುವ FORM FOR COMPLETION CERTIFICATE ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಒದಗಿಸಿರುತ್ತಾರೆ. (Annex-5)
- Neriga Grama Panchayath Office, Sarjapura Hobli, Anekal Taluk, Bangalore ರವರು ನೀಡಿರುವ ಹಿಡುವಳಿ ಪತ್ರ (OCCUPANCY PERMIT) ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಒದಗಿಸಿರುತ್ತಾರೆ. (Annex-6)

ಮೇಲಿನ ದಾಖಲೆಗಳೊಂದಿಗೆ ಉಲ್ಲೇಖ (2) ಅಂಶ-5 ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಿ ಕಟ್ಟಡವು I S Code:456-2000, IS Code:4926-2003, IS Code:516-1959 and 8112-1989 for 43 grade ನಲ್ಲಿ ನಿಗದಿಪಡಿಸಿರುವ ಮಾನದಂಡದಂತೆ ಕಟ್ಟಡದ ಕಾಂಕ್ರೀಟ್ ಕಂಬಗಳು (Columns) ತೊಲೆಗಳನ್ನು (Beams) ಮತ್ತು ಛಾವಣಿಯ (Slab) ವಿನ್ಯಾಸದಂತೆ ನಿರ್ಮಿಸಿದ್ದು, ಕಟ್ಟಡವು ಸದೃಢತೆಯಿಂದ ಇರುವುದು ಕಂಡುಬಂದಿರುತ್ತದೆಂದು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಲೋಕೋಪಯೋಗಿ ಉಪವಿಭಾಗ, ಆನೇಕಲ್ ರವರು ಉಲ್ಲೇಖ (5) ರ ಪತ್ರದಲ್ಲಿ ವರದಿ ಮಾಡಿರುತ್ತಾರೆ. ಉಲ್ಲೇಖ (2) ಮತ್ತು (3) ರ ಸರ್ಕಾರದ ಪತ್ರಗಳಲ್ಲಿ ಸೂಚಿಸಿರುವಂತೆ ಮೌಲ್ಯಮಾಪನ ಶುಲ್ಕವಾದ ಕಟ್ಟಡದ ಮೌಲ್ಯದ ಶೇ. 0.05% ರಷ್ಟು ಮೊತ್ತ ರೂ. 44,000/- (ರೂ. ನಲವತ್ತು ನಾಲ್ಕು ಸಾವಿರ ರೂಪಾಯಿಗಳು ಮಾತ್ರ) ಗಳನ್ನು Vishwa Vidyapeeth School ರವರು Bank of Baroda, ಡಿ.ಡಿ. ಸಂಖ್ಯೆ 232863 ದಿನಾಂಕ: 23.12.2021 ರಲ್ಲಿ ಪಾವತಿಸಿರುತ್ತಾರೆ.

Ushas Bhandari

Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

[Signature]

Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

ಸದರಿ ಸಂಸ್ಥೆಯವರು ನೀಡಿರುವ ಎಲ್ಲಾ ದಾಖಲೆಗಳನ್ನು ಪರಿಶೀಲಿಸಲಾಗಿ H. J. Radhakrishna Setty, Reg No. B.C.C/BL-3.6/SE-0195/2021-22 Consulting Structural Engineers ಮತ್ತು M/s. GEO Engineering Company Pvt.Ltd. #28, 5th Main, 3rd Phase, Peenya Industrial Area, Behind Bescom, Bangalore ರವರು ಕಟ್ಟಡವು ರಚನಾತ್ಮಕವಾಗಿ ಸುರಕ್ಷಿತವಾಗಿದೆಯೆಂದು ನೀಡಿರುವ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಪರಿಗಣಿಸಿ, ಹಾಗೂ ಕಟ್ಟಡವನ್ನು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆಯ ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಆನೇಕಲ್ ಉಪವಿಭಾಗ, ಆನೇಕಲ್ ರವರು ನೀಡಿರುವ ವರದಿ ಹಾಗೂ ಕಟ್ಟಡವು Structurally Stable ಇರುವುದಾಗಿ ಸಂಸ್ಥೆಯವರು ಸಲ್ಲಿಸಿರುವ ವರದಿಗಳಿಂದ ಕಂಡುಬಂದಿರುವುದರಿಂದ, ಈ ಕೆಳ ಸಹಿ ಮಾಡಿರುವವರು ದಿ: 07.12.2021 ರಂದು ಋದ್ಧಾಗಿ ಪರಿವೀಕ್ಷಿಸಿದ್ದು 'Vishwa Vidyapeeth School, ಕಟ್ಟಡವು Structurally Stable ಇದೆ ಎಂದು ನಿರಾಕ್ಷೇಪಣಾ ಪತ್ರವನ್ನು ಈ ಕೆಳಕಂಡ ಷರತ್ತುಗಳಿಗೆ ಒಳಪಟ್ಟು ನೀಡಲಾಗಿದೆ.

- ಇದರ ಅವಧಿಯು ಐದು ವರ್ಷದ್ದಾಗಿರುತ್ತದೆ.
- ಕಟ್ಟಡದ ಸುತ್ತಲೂ ಫ್ಲಾಗಿಂಗ್ ಕಾಂಕ್ರೀಟ್ ಅಳವಡಿಸುವುದು.
- ಕಟ್ಟಡದ ಟೇರೆಸ್‌ನಲ್ಲಿ ಪ್ಯಾರಾಪೆಟ್ 1.20 ಮೀಟರ್‌ಗಿಂತಲೂ ಕಡಿಮೆ ಇರದಂತೆ ನಿರ್ಮಿಸುವುದು.

ಉಳಿದಂತೆ, ಪ್ರಸ್ತಾಪಿತ ಕಟ್ಟಡದ Non - Structural Elements (Infrastructural facilities) ಗೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಸಿವಿಲ್ ಇಂಜಿನಿಯರ್, ಆರೋಗ್ಯಾಧಿಕಾರಿ, ಕಂದಾಯ ಅಧಿಕಾರಿ, ಮನಃಶಾಸ್ತ್ರಜ್ಞ, ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ಸ್ಥಳೀಯ ಸಂಸ್ಥೆಯ ಅಧಿಕಾರಿಗಳನ್ನೊಳಗೊಂಡ ಪರಿಷ್ಕಾ ತಂಡದವತಿಯಿಂದ ಪರಿಶೀಲಿಸಿ ನಿರಾಕ್ಷೇಪಣಾ ಪತ್ರವನ್ನು ಪಡೆಯತಕ್ಕದ್ದು ಹಾಗೂ "Fire safety Certificate" ಅನ್ನು ಮುಖ್ಯ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿಯಿಂದ ಪಡೆಯತಕ್ಕದ್ದು.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು,
ಲೋಕ., ಬೆಂಗಳೂರು ವಿಭಾಗ,
ಬೆಂಗಳೂರು.

Ushid Khandari

Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

[Signature]

Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

[Translation from Kannada version to English version]

Office of the Executive Engineer
PW.D. Bangalore Division
PWD Annexe Building, 2nd Floor
K.R. Circle, Bangalore-01

Government of Karnataka
Public Works Department

No.AE/BD/AE-3/ 23-24

To,
Secretary
Vishwa Vidyapeeth School, (A Unit of C.S.Education Trust)
Sy No. 72. Nekkundi. Dommasandra Raod,
Varthur Hobli, Anekal Taluk, Bangalore-660087

Sir


Subject: Regarding issuance of Safety certificate for building of CS. Education Trust, Vishwa Vidyapeeth School, Sy. No. 72, Nekkundi, Dommasandra Road, Varthur Hobli. Anekal Taluk, Bangalore.

- Reference 1. Proceedings of the meeting held on 19.09.2020 Under the chairmanship of the Chief Secretary. Primary and Secondary Education Department, Bangalore.
2. Govt. Circular No.PWD 69 BED 2019, dt: 10.11.2021
 3. Govt. Amendment order No. PWD 59 BED 2019 Dated: 20.11.2021
 4. Your letter dated: 12.11.2021
 5. Letter of the Asst. Executive Engineer, Public Works Department, Anekal Sub Division, Anekal.

With reference to the above subject, in the letter in ref (4) requested for issuance of the Safety certificate for building of C.S. Education Trust, Vishwa Vidyapeeth School, Sy No.72, Nekkundi. Dommasandra Road, Varthur Hobli. Anekal Taluk, Bangalore for the education purpose.

Regarding Writ Petition (Civil) No 484 (2004) in the judgment of the Supreme Court ordered the Executive Engineer, Public Works Department to verify the school/college building and issue "Structurally Stability Certificate and as per the direction of the proceedings in ref (1) intimated for structural evaluation for the building already constructed and issue certificate as per the National Building code guidelines, hence, submitted the report for the proposed building as under.

In the presence of the Assistant Engineer, Public Works Sub-Division, Anekal and Registered structural engineer of Vishwa Vidyapeeth School inspected the building of "CS Education Trust, Vishwa Vidyapeeth School, By No. 72, Nekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore.



Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.



Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

The building was constructed in the year 2020. In the Ground floor one principal room, one staff room, seventeen rooms, two computer lab, one library and art room and separate toilets for boys and girls existing. In the first floor Sastren rooms, one library, four lab and separate toilet for boys and girls existing. The width of the staircase is 1.50 meters.

Further, the building constructed before less than 5 years, regarding stability of the building, as mentioned in point 3 of ref (2) furnished below mentioned documents

* Plan approval from the Panchayathi Development Officer, Neriga Village Panchayathi, Anekal Taluk for CS Education Trust, Vishwa Vidyapeeth School, Sy. No. 74, Kekkundi, Dommasandra Road, Varthur Hobli, Anekal Taluk, Bangalore.

• Said building is structural plan given by 11.8 Radhakrishna Setty, Reg. No. B.C.C/BL-3.GSE-019/2021-22 of Specs Consulting Civil Engineers

*The institution have furnished the certificate of FORM FOR CERTIFICATE FOR SUB SURFACE INVESTIGATION (Annex-1) issued by ORO Engineering Company Private Limited, Reported that, the building of C.S Education Trust, Vishwa Vidyapeeth School, Sy No. 72, Nekkundi, Dommasandra Road, Varthur Hobli Anekal Taluk, Bangalore has been constructed as per the plan approved by Panchayathi Development Officer, Neriga Village Panchayathi, Anekal Taluk. (Annex-2)

*The institution have furnished the certificate of FORM FOR DY CERTIFICATE FOR COMPLETED WORK BUILDER/CONSTRUCTOR (Annex-3) issue by Cambridge Infrastructures and Leasing.


• The institution have furnished the certificate of FORM FOR CERTIFICATE FOR SUPERVISION OF WORK (Annex-4) issue by Cambridge Infrastructures and Leasing.


*The institution have furnished the certificate of FORM FOR COMPLETION CERTIFICATE (Annex-5) issue by H.J.Radhakrishna Setty Structural Engineer.

*The Institute have furnished the certificate of Occupancy Permit issued by the Neriga Grama Panchayath Office, Sarjapura Hobli, Anekal Taluk, Bangalore. (Annex-6).

The Asst. Executive Engineer, Public Works Sub-Division, Anekal in ref (5) reported that, along with the above documents as mentioned in point & of reference (2) inspected the building, the building has been constructed as per the concrete columns, beams and slabs as per the guidelines of IS Code: 456-2000, IS code: 4920-2003, IS Code: 616-1989 and 8112-1989 for 43 grade, the building is stable. As stated in the Govt. lettering (2) and (3), Vishwa Vidyapeeth School have paid Ra. 44,000/- (Rupees Forty Four Thousand Thousand only) 0.5% of the building value through D.D. No.232863, drawn on Bank of Baroda, dated: 23.12.2021.

On verification of all the documents produced by the said institute by considering the certificate issued by H.J. Radhakrishna Setty. Reg. No. BCC/BL-3.6/SE-0195/2021-22 Consulting Structural Engineers and M/s GEO Engineering Company Pvt. Ltd. # 28, 5th Main, 3rd Phase, Peenya Industrial Area, Behind Bescom, Bangalore that the


Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.


Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

building is structurally stable and from the report of the Asst. Executive Engineer, Public Works Department, Anekal Sub-Division, Anekal and the report submitted by the institute as Structurally Stable, the under signed have personally inspected the building on 07.12.2021, issued the No Objection Certificate stating that the building of "Vishwa Vidyapeeth School is Structurally Stable, subject to the below mentioned conditions.

* This certificate is valid for five years.

*Should construct the Flagging concrete around the building.


* Construct the parapet not less than 1.20 meters on the terrace of the building.

And regarding the Non-Structural Elements (Infrastructural facilities) of the proposed building, should get the NOC from the Civil Engineer, Health Officer, Revenue Officer, Psychologist, fire force officer, local body officer after inspection and should get "Fire Safety Certificate".

Yours faithfully.

Sd/- Executive Engineer

P.W. Department, Bangalore Division
Bangalore



ATTESTED

N. Peruvazhuthi
N. PERUVAZHUTHI, M.A. M.L.
Advocate - High Court
Notary Public - Govt. Of India
Whole Of India,
103, Sanjaynagar Main Road
Ashwathnagar, Bengaluru - 560 094

Ushar Mendani

Principal
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.

[Signature]

Director
Vishwa Vidyapeeth
Sy. No. 72, Nekkundi Dommasandra
Sarjapura Hobli, Anekal Taluku
Bengaluru - 560087.